

**From:** "Bartsch, David" <dbartsch@coalsource.com>  
**To:** "Abbot Stevenson" <abbot.stevenson@epa.state.oh.us>  
**Date:** 03/17/09 3:24 PM  
**Subject:** FW: Ohio Valley Coal Co Powhatan No 6 Mine  
**Attachments:** PrelimCompReview.pdf

Abbot, We received the attached email today. Please be advised that I omitted the pH from the No. 6 STP (Outfall 002) and will revise that report today. In addition, Outfall 011 only flowed on two days during February. We sampled one day and the Manganese was 2.8 mg/l. There was no opportunity to lower the monthly average. I'm told that the water in the pond is within compliance at this time so if it flows again, we'll be ok. Since the pond only flowed on two days, and our permit requires us to sample once every two weeks when flowing, we were in compliance, contrary to the report. If you have any questions, please contact me.

David L. Bartsch, P.E.  
Environmental Coordinator and Permit Administrator  
The Ohio Valley Coal Company  
56854 Pleasant Ridge Road  
Alledonia, OH 43902  
Phone: 740-926-1351 x260  
Fax: 740-926-9112  
Mobile: 740-310-9410

-----Original Message-----

From: DSW\_PCR@epa.state.oh.us [mailto:DSW\_PCR@epa.state.oh.us]  
Sent: Tuesday, March 17, 2009 11:45 AM  
To: Bartsch, David  
Cc: Abbot.Stevenson@epa.state.oh.us  
Subject: Ohio Valley Coal Co Powhatan No 6 Mine \* Preliminary Compliance Review - February 2009

The email address for this correspondence came from the Discharge Monitoring Report (DMR) submittal for the above listed facility. If you submit DMR data on behalf of the facility owner/permittee, please forward this email to the owner/permittee. The attached PDF file contains the Preliminary Compliance Review (PCR) for the above listed DMR. Receipt of this report indicates that Ohio EPA has screened the self-monitoring data submitted and has identified potential compliance problems.

Thank You.

